

Fire Alarm Control Panel Operating Instructions	
<p>Installed By: _____                      _____                      _____</p> <p>Per NFPA Standard:</p> <p><input type="checkbox"/> 72, Ch 3 - Local  <input type="checkbox"/> 72, Ch 4 - Auxiliary  <input type="checkbox"/> 72, Ch 4 - Remote Sta.  <input type="checkbox"/> 72, Ch 4 - Proprietary  <input type="checkbox"/> 72, Ch 4 - Central Sta.</p> <p>Dated: _____</p>	<p>Location: _____</p> <p><b>Normal Condition:</b> The Power LED (green) is on. All other LEDs are off.</p> <p><b>Alarm Condition:</b> The Alarm LED (red) turns on, the display shows the alarm location and zone, and the internal buzzer pulses.</p> <p style="padding-left: 20px;">To view other alarm messages: Press the ALARM review switch (down arrow).                      To silence audible devices: Press the Alarm Silence switch.                      To reset the system: Find the cause of the alarm condition, correct it, and press the Reset switch.</p> <p><b>Note:</b> Each new alarm will resound the audible devices, but you cannot resound them by pressing the Alarm Silence switch a second time.</p> <p><b>Supervisory Condition:</b> The Supervisory LED (yellow) turns on, the display shows the supervisory condition, location, and zone, and the internal buzzer pulses.</p> <p style="padding-left: 20px;">To view other supervisory messages: Press the SUPVR review switch (down arrow).                      To silence buzzer: Press Local Silence switch.                      To clear the system: Find the cause of supervisory condition, correct it, and press the Reset switch.</p> <p><b>Trouble Condition:</b> The system Trouble LED (yellow) turns on, the display shows the trouble location and zone, and the internal buzzer pulses.</p> <p style="padding-left: 20px;">To view other trouble messages: Press the TRBLE review switch (down arrow).                      To silence the buzzer: Press the Local Silence switch.                      To clear the system: Find the cause of the trouble and correct it. The system automatically clears itself upon correction of trouble condition.</p> <p><b>Monitor Condition:</b> The Monitor LED (yellow) turns on, the display shows monitor conditions, and the internal buzzer pulses during a non-fire alarm condition.</p> <p style="padding-left: 20px;">To view other monitor conditions: Press the MONTR review switch (down arrow).                      To clear system: The system automatically clears itself upon restoration of monitor condition.</p> <p><b>Fire Drill:</b> Notify the fire department before you run the test. All audible and visual notification appliances will operate during a drill.</p> <p style="padding-left: 20px;">To drill all notification appliances: Press the Drill switch.                      To end the drill: Press the Drill switch a second time, or press Alarm Silence.</p> <p>Frame these instructions and mount them next to the fire alarm control panel. For additional information, See the <i>System Operations Manual</i>.</p>
<p>For Service Contact:</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	
<p>Inspected By:</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>Date: _____</p>	
<p>Power Supply:</p> <p>Primary _____</p> <p>Location _____</p> <p>Fuses _____</p> <p>Secondary _____</p> <p>Type _____</p> <p>Specs. _____</p>	

STDOP007.CDR

Figure A-1: Fire alarm control panel operating instructions